

APPENDIX-L
FORM 'S'
(RULE 87(5))
FIRE AUDIT REPORT
YEAR-2026– 27

To,

ST. FRANCIS CONVENT CO ED SCHOOL
KHASRA NO. 6/4, OLD KHASRA NO. 6/1/1/2, KHAJURI KHURD, TEHSIL - HUZUR,
WARD NO. 62, ZONE NO. 15, PATEL NAGAR, RAISEN ROAD, BHOPAL [M.P]- 462022

Sub: Submission of Fire Audit Report of building Name ST FRANCIS CONVENT CO ED SCHOOL and Address – KHASRA NO. 6/4, OLD KHASRA NO. 6/1/1/2, KHAJURI KHURD, TEHSIL - HUZUR, WARD NO. 62, ZONE NO. 15, PATEL NAGAR, RAISEN ROAD, DISTRICT - BHOPAL (M.P.) – 462022

I am MR. DHEERAJ CHOUDHARY , B. TECH FIRE & SAFETY GOVT. APPROVED FIRE CONSULTANT has inspected your building/premises on 30.03.2026 and checked all fire equipment's/installations and have completed the fire audit of the said building/premises of ST. FRANCIS CONVENT CO ED SCHOOL, DISTRICT – BHOPAL [M.P] – 462022.

According to the use and character of occupancy, the campus includes building as “EDUCATIONAL BUILDING with Less than 15 meters in height.”.

BUILDING TYPE – EDUCATIONAL BUILDING

HEIGHT OF BUILDING – 11 METERS

PLOT AREA – 16408 SQ. M

BUILT – UP AREA - 4143.23 SQ.M

NO OF FLOORS - G+2

NO OF STUDENTS - 241 NOS

AUDIT PROCESS WILL BE DONE ACCORDING TO NATIONAL BUILDING CODE OF INDIA: 2016 FIRE AND LIFE SAFETY PROVISIONS WHICH COMES UNDER PLANNING COMMISSION OF INDIA

NATIONAL BUILDING CODE OF INDIA ENSURE THAT MIMIMUM FIRE FIGHTING LIABILITIES A BUILDING SHOULF FOLLOW: -

2. Details of fire system installed are as below: -

S. No.	Particular	Available/Installed or Not installed (As per requirements) (Give comments)	Comments for working of system (Attach details, if needed)
1.	Access	Available	The Building has wide access routes as per the NBC 2016 Part IV Table No. 07
2.	Wet Riser	Not Required	As per the NBC 2016 Part IV Table No. 7
3.	Down Comer	Available	As per the NBC 2016 Part 4 Table No. 07. Hydrant Pipe with Two-way Inlet is installed in the Ground Floor of the Building premises as per the requirements.
4.	Hose Reel	Available	As per the NBC 2016 Part 4 Table No. 07, Hose Reel Drum – 3 no's is installed in the building premises as per the requirements.
5.	Automatic Sprinkler System	Not Required	As per the NBC 2016 Part 4 Table No. 07.
6.	Yard Hydrant	Not Required	As per the NBC 2016 Part 4 Table No.07
7.	Underground Tank with draw off connection	Not Required	As per the NBC 2016 Part 4 Table No. 07
8.	Terrace Tank	Available	As per the NBC 2016 Part 4 Table No. 7, Terrace tank is available in the building premises as per the requirements.
9.	Fire Pump	Not Required	As per the NBC 2016 Part 4 Table No. 07
10.	Terrace Pump	Available	As per the NBC 2016 Part 4 Table No. 07. Terrace Pump is installed with Pump DOL Starter in the building premises as per the requirements.
11.	First Aid Fire Fighting Appliances	Available	First aid firefighting appliances such as portable ABC type fire extinguisher & CO2 Type Fire Extinguishers are installed in the building premises as per NBC 2016 Part IV Table No. 07
12.	Pressurization System	Available	As per the NBC 2016 Part 4 Table No. 7 Naturally Ventilated.
13.	Auto Detection System	Not Required	As per the NBC 2016 Part 4 Table No. 07

14.	Manual Operated Electrical Fire Alarm System	Available	As per the NBC 2016 Part 4 Table No. 07, Manual Call Point & Hooter is installed in the building premises as per the requirements
15.	P.A. System with talk back facility	Available	As per the NBC 2016 Part 4 Table No. 07, P. A. System is installed in the building premises with Amplifier & Speakers as per the requirements.
16.	Emergency Light	Not Required	As per the NBC 2016 Part 4 Table No. 07
17.	Auto D.G. Set	Not Available	As per the NBC 2016 Part 4 Table No. 07
18.	Illuminated Exit Sign	Available	As per the NBC 2016 Part 4 Table No. 07, EXIT Signage & other required Signage is installed & visible in the premises of the building as per the requirements.
19.	Means of Escape	Available	As per the NBC 2016 Part 4 Table No. 07, Fire Exit Door are available & Staircases for Fire Exit is available in the building premises as per the requirements at the time of emergency.
20.	Compartmentation	Available	As per the NBC 2016 Part 4 Table No 7
21.	MCP/ELCB	Available	Yes, Available, As Per the NBC 2016 Part 4 Table No. 07.
22.	Fireman Switch in Lift	Not Required	As Per NBC 2016 Part IV Table No. 07.
23.	Hose Boxes with Delivery Hose and Branch	Available	As per the NBC 2016 Part 4 Table No. 07. Single Door Hose Box with RRL Hose Pipe & Branch Pipe is installed in the building premises as per the requirements.
24.	Refuge Area	Available	Refuge Area is available
25	Any other installation	Not Required	Not Required

The Building Fire Safety Systems are Compliant with the provisions of the National Building Code [NBC] 2016 Part IV and relevant Indian Standards.

It is certified that the installed fire system as given above are in working condition.

Note: Report based on actual findings at the time of site inspection. Any further changes if applied will be administration responsibility.

Any changes in the building floor area, height or structure will render this certificate invalid. In such case, a fresh Fire Audit must be conducted & a new certificate is required to be obtained.

The Audit report has been made considering the requirements specifications NBC 2016 Part 4.

Date: 30.03.2026

Digitally signed by
DHEERAJ CHOUDHARY
Date: 2026.03.30
11:51:30 +05'30'

Name /Signature of fire Engineer/Consultant

Mr. DHEERAJ CHOUDHARY

Lic. No. 01/BFB/2024

Date of Issue – 30/03/2026

Date of Expiry – 29/03/2027

Ref. No. – FA/BHOPAL/09/MARCH/2026

