

## APPENDIX-L

### FORM'S

(See Rule 87 (571))

### Fire Audit Report

Year 2024-25

To,

St. Francis Convent Co-Ed School  
Patel Nagar, Bhopal, Madhya Pradesh 462022

Sir,

**Sub:** Submission of fire audit report of building name **St. Francis Convent Co-Ed School Patel Nagar Bhopal Madhya Pradesh**

I P.K DIWAN (Name of the Fire Engineers) have inspected your

building/premises on. 01/04/2024 (date) and checked all Fire Equipment's

installations and have completed the Fire Audit of the said Building Premises

Details of fire system installed areas below:

| S.No. | Particular | Available/ Installed<br>not installed<br>(As per<br>requirements) (give<br>comments) | comments for working<br>of system<br>(Attach details, if<br>needed) |
|-------|------------|--|---|
| 1.    | Access     | Available  | Available   |
| 2.    | Wet Riser  | Not Applicable   | Not Required as per as<br>NBC norms 2016-Part 4<br>Fire And Safety. |

|     |   |                |  |
|-----|---|----------------|--|
| 3.  | Down Comer                                | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |
| 4.  | Hose Reel                                 | Available      | Available, as per as NBC norms 2016-Part 4 Fire And Safety.    |
| 5.  | Automatic Sprinkler System                | Not Applicable | Not Required, as per as NBC norms 2016-Part 4 Fire And Safety. |
| 6.  | Yard Hydrant                              | Not Available  | Not Required, as per as NBC norms 2016-Part 4 Fire And Safety. |
| 7.  | Underground Tank with Draw off Connection | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |
| 8.  | Terrace Tanks                             | Available      | as per as NBC norms 2016-Part 4 Fire And Safety.               |
| 9.  | Fire Pump                                 | Available      | Available, as per as NBC norms 2016-Part 4 Fire And Safety.    |
| 10. | Terrace Pump                              | Not Available  | Not Required, as per as NBC norms 2016-Part 4 Fire And Safety. |
| 11. | First Aid Fire Fighting Appliances        | Available      | Available, fire extinguisher ABC type                          |




|     |  |                |  |
|-----|--|----------------|--|
|     |  |                | and CO2 type All are in working condition                      |
| 12. | Pressurization System                        | Available      | Available  |
| 13. | Auto Detection System                        | Not Applicable | Not required, As per as NBC norms 2016-Part 4 Fire And Safety. |
| 14. | Manual operated Electrical Fire Alarm System | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |
| 15. | P.A. System with talk back Facility          | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |
| 16. | Emergency Light                              | Available      | Available  |
| 17. | Auto D.G. Set                                | Not Available  | Not Required, as per as NBC norms 2016-Part 4 Fire And Safety. |
| 18. | Illuminated Exit Sign                        | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |
| 19. | Means of Escape                              | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |
| 20. | Compartmentation                             | Available      | Available as per as NBC norms 2016-Part 4 Fire And Safety.     |

मध्यप्रदेश राजपत्र, दिनांक 1 सितम्बर 2020

|     |   |               |  |
|-----|---|---------------|--|
| 21. | MCB/ELCB                                    | Available     | Installed  |
| 22. | Fireman Switch in Lift                      | Not Available | Not Available                                    |
| 23. | Hose Boxes with Delivery<br>Hose and Branch | Available     | Available, on each floor<br>as per as NBC norms. |
| 24. | Refuge Area                                 | Available     | Outside Of building                              |
| 25. | Any other installation                      | Available     | Fire Bucket Available                            |

It is certified that the installed Fire system as given above are in working condition and safe.

  
P. K. DIWAN  
(B.E. FIRE)  
Reg.No. 06/BFB/2021


Signature

Name of Fire Engineer

L No. : 06/BFB/2021


Add :41, Jyoti nagar, Hoshangabad  
Road, Bhopal





मध्यप्रदेश राजपत्र, दिनांक 1 सितम्बर 2020



  
P. K. DIWAN  
(B.E. FIRE)  
Reg.No. 06/BFB/2021